

Energistyrelsen
Amaliegade 44
1256 København K

Att.: Nina Lassen

Harboøre den 14.07.2011

Vedr. Deres J.nr. 2109/1487-0001 Høringssvar på VVM-redegørelse for havvindmøllepark i Nissum Bredning.

Driftsselskabet Rønland Havvindmøllepark I/S er et fælles driftsselskab for de 4 stk. 2,3 MW Siemens vindmøller, som er nærmeste nabo til de planlagte vindmøller øst for sejlrenden i Nissum Bredning.

Driftsselskabet varetager ejernes fælles interesser og præsenterer herved deres bemærkninger og indsigelser i forhold til ovennævnte VVM høring.

Indledningsvis skal vi bemærke, at vi har en positiv holdning til vindmølleudbygningen både on- og off-shore. Vi vil dog anfægte placeringen i Nissum Bredning vest for sejlrenden, da placeringen er så tæt på vore vindmøller, at det vil medføre væsentlige tab i indtjeningen, øge omkostningerne til drift og vedligehold samt forkorte møllernes levetid på grund af øget turbulens og vindskygge fra de planlagte vindmøller.

For at kvantificere produktionstab har vi bedt Energi og Miljødata beregne tabet. Produktionstab er beregnet ud fra hver af de 4 alternativer, som det fremgår af de vedhæftede pdf-filer. Konklusioner er, at tabet kan beregnes til 885 MWh/år for den placering, hvor afstanden mellem møllerne er mindst. Hertil kommer de øgede omkostninger til drift og vedligehold samt levetidsforkortelsen. Det er imidlertid vanskeligt at kapitalisere disse forhold, hvilket vi derfor endnu ikke har gjort.

Med baggrund i ovenstående mener vi, at placeringen så tæt på de eksisterende møller er så problematisk, at den bør opgives. Der er præcedens for, at der ved off-shore udbud fastsættes en friholdelseszone på ikke under 3 km. mellem parker, som ikke opføres under samme udbud. Det må derfor være rimeligt, om Energistyrelsen fastlægger en tilsvarende minimum afstand til de nye møller i Nissum Bredning.

Såfremt Energistyrelsen vælger ikke at tage hensyn til vor indsigelse, må vi forbeholde os at blive holdt skadesløs for vore tab og øgede omkostninger.

For Driftsselskabet Rønland Havvindmøllepark I/S

Knud Vrist



Per Lauritsen



Project: Harboøre_juli-11
 Description: Baseret på skælerede møller

Printed/Page: 05-07-2011 19:21 / 1
 Licensed user: EMD International A/S
 Niels Jernesvej 10
 DK-9220 Aalborg Ø
 +45 9635 4444
 Per Nielsen, pn@emd.dk
 Calculated: 05-07-2011 18:56/2.8.244

PARK - Main Result

Calculation: L1

Wake Model N.O. Jensen (RISØ/EMD)


Calculation Settings
 Air density calculation mode Individual per WTG
 Result for WTG at hub altitude 1,235 kg/m³ to 1,241 kg/m³
 Air density relative to standard 101,3 %
 Hub altitude above sea level (asl) 78,0 m to 130,0 m
 Annual mean temperature at hub alt. 8,2 °C to 8,5 °C
 Pressure at WTGs 997,4 hPa to 1.003,7 hPa

Wake Model Parameters
 Wake Decay Constant 0,040 Offshore & Water areas

Wake calculation settings
 Angle [°] Wind speed [m/s]
 start end step start end step
 0,5 360,0 1,0 0,5 30,5 1,0

Wind statistics DK DANMARK '07.wvs
 Regional Correction Factor 1,25

WASP version WASP 10.1 for Windows RVEA0164 1, 9, 5, 0



Scale 1:50.000
 △ New WTG * Existing WTG ⊙ Site Data

Key results for height 80,0 m above ground level

Terrain ETRS 89 Zone: 32

East	North	Name of wind distribution	Type	Wind energy [kWh/m ²]	Mean wind speed [m/s]	Equivalent wind roughness
A 453.173	6.280.650	Site data 12 sectors; Radius: 28.022 m (1)	WASP (WASP 10.1 for Windows RVEA0164 1, 9, 5, 0)	8.409	9,6	-0,8

Calculated Annual Energy for Wind Farm

WTG combination	Result PARK [MWh/y]	Result-10,0% [MWh]	GROSS (no loss) Free WTGs [MWh/y]	Park efficiency [%]	Specific results ^{a)}			
					Capacity factor [%]	Mean WTG result [MWh/y]	Full load hours [Hours/year]	Mean wind speed @ hub height [m/s]
Wind farm	352.266,4	317.039,8	377.354,5	93,4	48,1	21.136,0	4.216	10,2
New WTGs only	313.884,9	282.496,4	336.908,2	93,2	48,8	25.681,5	4.280	10,5
Existing park WTGs only	38.381,6	34.543,4	40.446,3	94,9	42,8	8.635,9	3.755	9,5
Existing park WTGs without new WTGs	39.214,4	35.292,9	40.446,3	97,0		8.823,2		0,0
Reduction for existing park WTGs caused by new	832,8	749,5						

^{a)} Based on Result-10,0%

Calculated Annual Energy for each of 11 new WTGs with total 66,0 MW rated power

WTG type	Terrain	Valid	Manufact.	Type-generator	Power, rated [kW]	Rotor diameter [m]	Hub height [m]	Power curve Creator Name	Annual Energy		Park	
									Result [MWh]	Result-10,0% [MWh]	Efficiency [%]	Mean wind speed [m/s]
5 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	29.160,3	26.244	95,44	10,44	
6 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.601,6	25.741	93,49	10,46	
7 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.337,7	25.504	92,61	10,46	
8 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.314,1	25.483	92,47	10,47	
9 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.647,2	25.782	93,52	10,48	
10 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	29.112,0	26.201	95,10	10,45	
11 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.396,8	25.557	92,71	10,46	
12 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.076,8	25.269	91,60	10,47	
13 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.055,3	25.250	91,49	10,48	
14 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.295,0	25.466	92,25	10,49	
15 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.888,2	25.999	94,16	10,49	

^{a)} Included in array losses is influence from 4 WTG(s) in the neighborhood, which has status as "Reference WTGs", see separate report to identify these.

Project: Harbøre_juli-11
 Description: Baseret på skalerede møller

Printed/Page: 05-07-2011 19:21 / 2
 Licensed user: EMD International AIS
 Niels Jernesvej 10
 DK-9220 Aalborg Ø
 +45 9635 4444
 Per Nielsen, pn@emd.dk
 Calculated: 05-07-2011 18:56/2.8.244

PARK - Main Result

Calculation: L1

Calculated Annual Energy for each of 4 existing park WTGs with total 9,2 MW rated power

Terrain	WTG type		Type-generator	Power, rated	Rotor diameter	Hub height	Power curve Creator Name	Calculated prod. without new WTGs [MWh]	Annual Energy After New WTGs [MWh]	Decrease due to new WTGs [MWh %]	Park Efficiency [%]
	Valid	Manufact.									
1 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.739,9	9.481,1	258,8 2,7	93,54
2 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.738,9	9.519,6	219,3 2,3	94,15
3 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.785,2	9.590,4	194,8 2,0	94,94
4 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.950,4	9.790,5	159,9 1,6	96,96

WTG siting

ETRS 89 Zone: 32				Z	Row data/Description
East	North				
ETRS 89 Zone: 32				[m]	
1 Exist	452.277	6.279.871	0,0	BONUS 2.3 MW 2300-400 82.4 IO! hub: 78,8 m (5)	
2 Exist	452.355	6.279.595	0,0	BONUS 2.3 MW 2300-400 82.4 IO! hub: 78,8 m (6)	
3 Exist	452.433	6.279.321	0,0	BONUS 2.3 MW 2300-400 82.4 IO! hub: 78,8 m (7)	
4 Exist	452.511	6.279.047	0,0	BONUS 2.3 MW 2300-400 82.4 IO! hub: 78,8 m (8)	
5 New	453.670	6.279.842	0,0	-27,4°, 428,7 m	
6 New	453.477	6.280.024	0,0		
7 New	453.283	6.280.407	0,0		
8 New	453.089	6.280.789	0,0		
9 New	452.895	6.281.172	0,0		
10 New	454.395	6.279.803	0,0	-27,4°, 428,7 m	
11 New	454.202	6.280.186	0,0		
12 New	454.008	6.280.568	0,0		
13 New	453.814	6.280.950	0,0		
14 New	453.620	6.281.333	0,0		
15 New	453.426	6.281.715	0,0		

Project: Harboøre_juli-11 Description: Baseret på skalerede nye møller.

Printed/Page: 05-07-2011 19:19 / 1
 Licensed user: EMD International A/S1
 Niels Jernesvej 10
 DK-9220 Aalborg Ø
 +45 9635 4444
 Per Nielsen, pn@emd.dk
 Calculated: 05-07-2011 19:17/2.8.244

PARK - Main Result

Calculation: L2

Wake Model: N.O. Jensen (RISØ/EMD)


Calculation Settings
 Air density calculation mode: Individual per WTG
 Result for WTG at hub altitude: 1,240 kg/m³ to 1,241 kg/m³
 Air density relative to standard: 101,3 %
 Hub altitude above sea level (asl): 78,0 m to 90,0 m
 Annual mean temperature at hub alt.: 8,4 °C to 8,5 °C
 Pressure at WTGs: 1.002,3 hPa to 1.003,7 hPa

Wake Model Parameters
 Wake Decay Constant: 0,040 Offshore & Water areas

Wake calculation settings
 Angle [°]: start end step start end step
 Wind speed [m/s]: 0,5 360,0 1,0 0,5 30,5 1,0

Wind statistics
 Regional Correction Factor: DK DANMARK '07.wvs
 1,25

WAsP version
 WAsP 10.1 for Windows RVEA0164 1, 9, 5, 0



Scale 1:75.000
 λ New WTG * Existing WTG ⊙ Site Data

Key results for height 50,0 m above ground level

Terrain	ETRS 89 Zone: 32	East	North	Name of wind distribution	Type	Wind energy [kWh/m²]	Mean wind speed [m/s]	Equivalent roughness
A	453.173	6.280.650	Site data	12 sectors; Radius: 28.022 m (1)	WAsP (WAsP 10.1 for Windows RVEA0164 1, 9, 5, 0)	6.757	8,9	-0,5

Calculated Annual Energy for Wind Farm

WTG combination	Result PARK [MWh/y]	Result-10,0% [MWh]	GROSS (no loss) Free WTGs [MWh/y]	Park efficiency [%]	Specific results a) Capacity factor [%]	Mean WTG result [MWh/y]	Full load hours [Hours/year]	Mean wind speed @ hub height [m/s]
Wind farm	376.746,9	339.072,2	407.569,1	92,4	41,5	18.837,3	3.638	9,7
New WTGs only	337.990,6	304.191,5	367.123,8	92,1	41,3	21.728,0	3.621	9,8
Existing park WTGs only	38.756,3	34.880,7	40.445,4	95,8	43,3	8.720,2	3.791	9,5
Existing park WTGs without new WTGs	39.213,4	35.292,1	40.445,4	97,0		8.823,0		0,0
Reduction for existing park WTGs caused by new	457,1	411,4						

a) Based on Result-10,0%

Calculated Annual Energy for each of 14 new WTGs with total 84,0 MW rated power

WTG type	Terrain	Valid	Manufact.	Type-generator	Power, rated [kW]	Rotor diameter [m]	Hub height [m]	Power curve Creator Name	Annual Energy Result [MWh]	Annual Energy Result-10,0% [MWh]	Park Efficiency [%]	Mean wind speed [m/s]
5 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	24.749,9	22.275	94,58	9,78	
6 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	24.271,9	21.845	92,67	9,79	
7 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	24.092,7	21.683	91,90	9,80	
8 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	24.053,7	21.648	91,73	9,80	
9 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	24.185,0	21.767	92,13	9,81	
10 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	24.490,5	22.041	93,31	9,81	
11 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	24.861,2	22.375	94,92	9,79	
12 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	24.118,9	21.707	92,01	9,80	
13 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	23.697,4	21.328	90,38	9,80	
14 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	23.505,4	21.155	89,63	9,80	
15 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	23.499,5	21.150	89,60	9,80	
16 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	23.648,3	21.283	90,11	9,81	
17 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	24.067,7	21.661	91,68	9,81	

To be continued on next page...

*) Included in array losses is influence from 4 WTG(s) in the neighborhood, which has status as "Reference WTGs", see separate report to identify these.

Project: Harboøre_juli-11 Description: Baseret på skalerede nye møller.

Printed/Page: 05-07-2011 19:19 / 2
 Licensed user: EMD International A/S1
 Niels Jernesvej 10
 DK-9220 Aalborg Ø
 +45 9635 4444
 Per Nielsen, pn@emd.dk
 Calculated: 05-07-2011 19:17/2.8.244

PARK - Main Result

Calculation: L2

...continued from previous page

Terrain	Valid	WTG type Manufact.	Type-generator	Power, rated [kW]	Rotor diameter [m]	Hub height [m]	Power curve Creator Name	Annual Energy		Park Efficiency [%]	Mean wind speed [m/s]
								Result [MWh]	Result-10,0% [MWh]		
18 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER Dummy-6MW	24.748,4	22.274	94,26	9,81

Calculated Annual Energy for each of 4 existing park WTGs with total 9,2 MW rated power

Terrain	Valid	WTG type Manufact.	Type-generator	Power, rated [kW]	Rotor diameter [m]	Hub height [m]	Power curve Creator Name	Calculated prod. without new WTGs [MWh]	Annual Energy After New WTGs [MWh]	Decrease due to new WTGs [MWh %]	Park Efficiency [%]
1 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.739,8	9.602,4	137,3 1,4	94,74
2 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.738,3	9.617,6	120,7 1,2	95,12
3 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.785,0	9.679,5	105,5 1,1	95,83
4 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.950,3	9.856,8	93,5 0,9	97,62

WTG siting

ETRS 89 Zone: 32

	East	North	Z	Row data/Description
	ETRS 89 Zone: 32			
			[m]	
1 Exist	452.277	6.279.871	0,0	BONUS 2.3 MW 2300-400 82.4 !O! hub: 78,8 m (5)
2 Exist	452.355	6.279.595	0,0	BONUS 2.3 MW 2300-400 82.4 !O! hub: 78,8 m (6)
3 Exist	452.433	6.279.321	0,0	BONUS 2.3 MW 2300-400 82.4 !O! hub: 78,8 m (7)
4 Exist	452.511	6.279.047	0,0	BONUS 2.3 MW 2300-400 82.4 !O! hub: 78,8 m (8)
5 New	454.079	6.280.515	0,0	-27,0°, 371,3 m
6 New	453.914	6.280.847	0,0	
7 New	453.748	6.281.180	0,0	
8 New	453.583	6.281.512	0,0	
9 New	453.418	6.281.844	0,0	
10 New	453.252	6.282.177	0,0	
11 New	454.826	6.280.474	0,0	-27,0°, 371,3 m
12 New	454.661	6.280.806	0,0	
13 New	454.495	6.281.139	0,0	
14 New	454.330	6.281.471	0,0	
15 New	454.165	6.281.804	0,0	
16 New	453.999	6.282.136	0,0	
17 New	453.834	6.282.468	0,0	
18 New	453.669	6.282.801	0,0	

Project
Harboøre juli-11

Printed/Page
05-07-2011 19:20 / 1
Licensed user:
EMD International A/S1
Niels Jernesvej 10
DK-9220 Aalborg Ø
+45 9635 4444
Per Nielsen, pn@emd.dk
Calculated:
05-07-2011 19:04/2.8.244

PARK - Main Result

Calculation: L3

Wake Model N.O. Jensen (RISØ/EMD)


Calculation Settings
Air density calculation mode Individual per WTG
Result for WTG at hub altitude 1,240 kg/m³ to 1,241 kg/m³
Air density relative to standard 101,3 %
Hub altitude above sea level (asl) 78,0 m to 90,0 m
Annual mean temperature at hub alt. 8,4 °C to 8,5 °C
Pressure at WTGs 1.002,3 hPa to 1.003,7 hPa

Wake Model Parameters
Wake Decay Constant 0,040 Offshore & Water areas

Wake calculation settings
Angle [°] Wind speed [m/s]
start end step start end step
0,5 360,0 1,0 0,5 30,5 1,0

Wind statistics
Regional Correction Factor DK DANMARK '07.wvs
1,25

WAsP version WAsP 10.1 for Windows RVEA0164 1, 9, 5, 0



Scale 1:50.000
* Existing WTG ⊙ Site Data

Key results for height 50,0 m above ground level

Terrain	ETRS 89 Zone: 32	East	North	Name of wind distribution	Type	Wind energy [kWh/m²]	Mean wind speed [m/s]	Equivalent roughness
A	453.173	6.280.650	Site data	12 sectors; Radius: 28.022 m (1)	WAsP (WAsP 10.1 for Windows RVEA0164 1, 9, 5, 0)	6.757	8,9	-0,5

Calculated Annual Energy for Wind Farm

WTG combination	Result PARK [MWh/y]	Result-10,0% [MWh]	GROSS (no loss) Free WTGs [MWh/y]	Park efficiency [%]	Specific results ^{a)}			Mean wind speed @ hub height [m/s]
					Capacity factor [%]	Mean WTG result [MWh/y]	Full load hours [Hours/year]	
Wind farm	324.477,7	292.029,9	354.103,9	91,6	41,0	18.251,9	3.596	9,7
New WTGs only	286.148,4	257.533,6	313.657,5	91,2	40,8	21.461,1	3.577	9,8
Existing park WTGs only	38.329,3	34.496,3	40.446,4	94,8	42,8	8.624,1	3.750	9,5
Existing park WTGs without new WTGs	39.214,4	35.293,0	40.446,4	97,0		8.823,2		0,0
Reduction for existing park WTGs caused by new	885,2	796,7						

^{a)} Based on Result-10,0%

Calculated Annual Energy for each of 12 new WTGs with total 72,0 MW rated power

WTG type	Terrain	Valid	Manufact.	Type-generator	Power, rated [kW]	Rotor diameter [m]	Hub height [m]	Power curve Creator	Name	Annual Energy		Park	
										Result [MWh]	Result-10,0% [MWh]	Efficiency [%]	Mean wind speed [m/s]
5 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	24.506,6	22.056	94,24	9,74	
6 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	23.929,4	21.536	91,84	9,75	
7 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	23.673,7	21.306	90,71	9,77	
8 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	23.615,9	21.254	90,36	9,78	
9 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	23.804,8	21.424	90,91	9,80	
10 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	24.269,6	21.843	92,56	9,81	
11 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	24.550,1	22.095	94,10	9,76	
12 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	23.773,6	21.396	91,03	9,77	
13 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	23.392,2	21.053	89,42	9,78	
14 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	23.321,0	20.989	89,08	9,79	
15 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	23.438,0	21.094	89,45	9,80	
16 A	No	DUMMY	-6.000	6.000	125,0	90,0	USER	Dummy-6MW	23.673,6	21.486	91,10	9,80	

^{a)} Included in array losses is influence from 4 WTG(s) in the neighborhood, which has status as "Reference WTGs", see separate report to identify these.

Project

Harboøre_juli-11

Printed/Page

05-07-2011 19:20 / 2

Licensed user:

EMD International A/S1

Niels Jernesvej 10

DK-9220 Aalborg Ø

+45 9635 4444

Per Nielsen, pn@emd.dk

Calculated:

05-07-2011 19:04/2.8.244

PARK - Main Result

Calculation: L3

Calculated Annual Energy for each of 4 existing park WTGs with total 9,2 MW rated power

Terrain	WTG type		Power, rated	Rotor diameter	Hub height	Power curve Creator Name	Annual Energy	Park Efficiency		
	Valid	Manufact. Type-generator							Calculated prod. without new WTGs	After New WTGs
			[kW]	[m]	[m]		[MWh]	[MWh]	[MWh %]	[%]
1 A	No	BONUS 2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.739,9	9.460,1	279,9 2,9	93,33
2 A	No	BONUS 2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.738,9	9.498,3	240,5 2,5	93,93
3 A	No	BONUS 2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.785,2	9.585,3	199,9 2,0	94,89
4 A	No	BONUS 2.3 MW-2.300/400	2.300	82,4	78,8	EMD Level 0 - Calculated -- 01-2002	9.950,4	9.785,6	164,9 1,7	96,91

WTG siting

ETRS 89 Zone: 32

East

North

Z

Row data/Description

	East	North	Z [m]	Row data/Description
1 Exist	452.277	6.279.871	0,0	BONUS 2.3 MW 2300-400 82.4 !O! hub: 78,8 m (5)
2 Exist	452.355	6.279.595	0,0	BONUS 2.3 MW 2300-400 82.4 !O! hub: 78,8 m (6)
3 Exist	452.433	6.279.321	0,0	BONUS 2.3 MW 2300-400 82.4 !O! hub: 78,8 m (7)
4 Exist	452.511	6.279.047	0,0	BONUS 2.3 MW 2300-400 82.4 !O! hub: 78,8 m (8)
5 New	453.718	6.279.683	0,0	-27,3°, 361,0 m
6 New	453.555	6.280.005	0,0	
7 New	453.393	6.280.327	0,0	
8 New	453.230	6.280.650	0,0	
9 New	453.067	6.280.972	0,0	
10 New	452.905	6.281.294	0,0	
11 New	454.358	6.279.787	0,0	-27,3°, 361,0 m
12 New	454.195	6.280.109	0,0	
13 New	454.033	6.280.432	0,0	
14 New	453.870	6.280.754	0,0	
15 New	453.707	6.281.076	0,0	
16 New	453.545	6.281.398	0,0	

Project: Harboøre_juli-11 Description: Baseret på skalerede møller

Printed/Page: 05-07-2011 19:22 / 1
 Licensed user: EMD International A/S1
 Niels Jernesvej 10
 DK-9220 Aalborg Ø
 +45 9635 4444
 Per Nielsen, pn@emd.dk
 Calculated: 05-07-2011 18:22/2.8.244

PARK - Main Result

Calculation: L0

Wake Model N.O. Jensen (RISØ/EMD)


Calculation Settings
 Air density calculation mode Individual per WTG
 Result for WTG at hub altitude 1,235 kg/m³ to 1,241 kg/m³
 Air density relative to standard 101,3 %
 Hub altitude above sea level (asl) 78,0 m to 130,0 m
 Annual mean temperature at hub alt. 8,2 °C to 8,5 °C
 Pressure at WTGs 997,4 hPa to 1.003,7 hPa

Wake Model Parameters
 Wake Decay Constant 0,040 Offshore & Water areas

Wake calculation settings
 Angle [°] Wind speed [m/s]
 start end step start end step
 0,5 360,0 1,0 0,5 30,5 1,0

Wind statistics
 Regional Correction Factor DK DANMARK '07.wvs 1,25

WAsP version WAsP 10.1 for Windows RVEA0164 1, 9, 5, 0



Scale 1:75.000
 ^ New WTG * Existing WTG ⊙ Site Data

Key results for height 50,0 m above ground level

Terrain ETRS 89 Zone: 32

East	North	Name of wind distribution	Type	Wind energy [kWh/m²]	Mean wind speed [m/s]	Equivalent roughness
A 453.173	6.280.650	Site data 12 sectors; Radius: 28.022 m (1)	WAsP (WAsP 10.1 for Windows RVEA0164 1, 9, 5, 0)	6,757	8,9	-0,5

Calculated Annual Energy for Wind Farm

WTG combination	Result PARK [MWh/y]	Result-10,0% [MWh]	GROSS (no loss) Free WTGs [MWh/y]	Park efficiency [%]	Specific results ^{a)}			Mean wind speed @h ub height [m/s]
					Capacity factor [%]	Mean WTG result [MWh/y]	Full load hours [Hours/year]	
Wind farm	438.030,2	394.227,2	469.773,5	93,2	48,3	21.901,5	4.230	10,3
New WTGs only	399.397,0	359.457,3	429.328,2	93,0	48,8	25.675,5	4.279	10,5
Existing park WTGs only	38.633,3	34.769,9	40.445,3	95,5	43,1	8.692,5	3.779	9,5
Existing park WTGs without new WTGs	39.213,3	35.292,0	40.445,3	97,0		8.823,0		0,0
Reduction for existing park WTGs caused by new	580,0	522,0						

^{a)} Based on Result-10,0%

Calculated Annual Energy for each of 14 new WTGs with total 84,0 MW rated power

WTG type	Terrain Valid	Manufact.	Type-generator	Power, rated [kW]	Rotor diameter [m]	Hub height [m]	Power curve Creator Name	Annual Energy		Park Efficiency [%]	Mean wind speed [m/s]
								Result [MWh]	Result-10,0% [MWh]		
5 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	29.264,6	26.338	95,56	10,46
6 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.715,9	25.844	93,70	10,47
7 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.464,5	25.618	92,85	10,48
8 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.391,9	25.553	92,58	10,48
9 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.470,3	25.623	92,81	10,49
10 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.755,5	25.880	93,76	10,49
11 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	29.131,4	26.218	95,10	10,46
12 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.390,0	25.551	92,60	10,47
13 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	27.999,4	25.199	91,29	10,48
14 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	27.870,6	25.084	90,84	10,49
15 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	27.909,3	25.118	90,97	10,49
16 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER Dummy 140m rotor	28.146,7	25.332	91,71	10,49

To be continued on next page...

^{a)} Included in array losses is influence from 4 WTG(s) in the neighborhood, which has status as "Reference WTGs", see separate report to identify these.

Project: Harboøre_juli-11
 Description: Baseret på skalerede møller

Printed/Page: 05-07-2011 19:22 / 2

Licensed user:
 EMD International A/S1
 Niels Jernesvej 10
 DK-9220 Aalborg Ø
 +45 9635 4444
 Per Nielsen, pn@emd.dk
 Calculated:
 05-07-2011 18:22/2.8.244

PARK - Main Result

Calculation: L0

...continued from previous page

WTG type		Terrain	Valid	Manufact.	Type-generator	Power, rated	Rotor diameter	Hub height	Power curve Creator	Name	Annual Energy		Park	
											Result	Result-10,0%	Efficiency	Mean wind speed
						[kW]	[m]	[m]			[MWh]	[MWh]	[%]	[m/s]
17 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER	Dummy 140m rotor	28.634,2	25.771	93,30	10,49		
18 A	No	DUMMY	-6.000	6.000	140,0	130,0	USER	Dummy 140m rotor	29.252,7	26.327	95,34	10,49		

Calculated Annual Energy for each of 4 existing park WTGs with total 9,2 MW rated power

WTG type		Terrain	Valid	Manufact.	Type-generator	Power, rated	Rotor diameter	Hub height	Power curve Creator	Name	Annual Energy		Park Efficiency	
											Calculated prod. without new WTGs	After New WTGs		Decrease due to new WTGs
						[kW]	[m]	[m]			[MWh]	[MWh]	[MWh %]	[%]
1 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD	Level 0 - Calculated -- 01-2002	9.739,8	9.566,4	173,3	1,8	94,38	
2 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD	Level 0 - Calculated -- 01-2002	9.738,3	9.582,7	155,6	1,6	94,77	
3 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD	Level 0 - Calculated -- 01-2002	9.785,0	9.653,1	131,9	1,3	95,56	
4 A	No	BONUS	2.3 MW-2.300/400	2.300	82,4	78,8	EMD	Level 0 - Calculated -- 01-2002	9.950,3	9.831,0	119,2	1,2	97,36	

WTG siting

ETRS 89 Zone: 32				Z	Row data/Description
East	North				
ETRS 89 Zone: 32				[m]	
1 Exist	452.277	6.279.871	0,0	BONUS 2.3 MW 2300-400 82.4 !O!	hub: 78,8 m (5)
2 Exist	452.355	6.279.595	0,0	BONUS 2.3 MW 2300-400 82.4 !O!	hub: 78,8 m (6)
3 Exist	452.433	6.279.321	0,0	BONUS 2.3 MW 2300-400 82.4 !O!	hub: 78,8 m (7)
4 Exist	452.511	6.279.047	0,0	BONUS 2.3 MW 2300-400 82.4 !O!	hub: 78,8 m (8)
5 New	454.271	6.280.072	0,0	-27,6°, 423,9 m	
6 New	454.078	6.280.450	0,0		
7 New	453.886	6.280.827	0,0		
8 New	453.693	6.281.205	0,0		
9 New	453.501	6.281.583	0,0		
10 New	453.308	6.281.960	0,0		
11 New	454.977	6.280.193	0,0	-27,6°, 423,9 m	
12 New	454.785	6.280.571	0,0		
13 New	454.592	6.280.948	0,0		
14 New	454.400	6.281.326	0,0		
15 New	454.207	6.281.704	0,0		
16 New	454.015	6.282.081	0,0		
17 New	453.822	6.282.459	0,0		
18 New	453.630	6.282.837	0,0		