


# Session 3

Losses from increased level of RE - 11 kV PF case study



**COWI**


# Homework



Feeder C

Feeder B

Feeder A



### Consumption:

Feeder A: 13 MWh/hh/year

Feeder B: 7 MWh/hh/year


Feeder C: 7 MWh/hh/year

### PV size:

Feeder A: ~ 14kW

Feeder B: ~ 8 kW

Feeder C: ~ 8 kW



# Case Study- PF SSEG

- 11 kV grid with three feeders, A, B and C and 4510 attached households
- The 11 kV grid is connected to single feeding source, a 33 kV distribution grid. Here named “External Grid”(top-down) (slack)
- Let’s study some cases and see how the loss pattern changes with SSEG

Assumptions:

??


??

# Case Study- PF SSEG

- 11 kV grid with three feeders, A, B and C and 4510 attached households
- The 11 kV grid is connected to single feeding source, a 33 kV distribution grid. Here named “External Grid”(top-down) (slack)
- Let’s study some cases and see how the loss pattern changes with SSEG
- Assumptions and questions:
  - Voltage will increase locally
  - Consumption close to the production – reduced distribution
  - → Reduced system losses
  - Increased share of SSEG – exceeding production compared to consumption
  - More distribution throughout the grid
  - → increased losses
  - But where is the breaking point?
  - What solutions can be used to enable more SSEG?

# Case 1 – External Grid keeps active power balance

- External Grid keeps active power balance (slack)
  - The house hold loads are at their highest
  - No SSEG connected
- 
- This case represents the base case, no SSEG and high load is the “worst” operating case for the power grid during these conditions.



# Case 1 – External Grid keeps active power balance

- External Grid keeps active power balance (slack)
- The house hold loads are at their highest
- No SSEG connected
- This case represents the base case, no SSEG and high load is the “worst” operating case for the power grid during these conditions.

- Grid losses: 0.32MW
- Voltages decreasing due to high consumption from hh



# Case 1 – External Grid keeps active power balance

Load Flow Calculation					Grid Summary	
AC Load Flow, balanced, positive sequence			Automatic Model Adaptation for Convergence		No	
Automatic tap adjustment of transformers			No	Max. Acceptable Load Flow Error for		
Consider reactive power limits			No	Nodes		1,00 kVA
				Model Equations		0,10 %
Grid: LV-Grid		System Stage: LV-Grid		Study Case: Study Case		Annex: / 1
Grid: LV-Grid		Summary				
No. of Substations	0	No. of Busbars	17	No. of Terminals	0	No. of Lines 15
No. of 2-w Trfs.	1	No. of 3-w Trfs.	0	No. of syn. Machines	0	No. of asyn.Machines 0
No. of Loads	15	No. of Shunts/Filters	0	No. of SVS	0	
Generation	=	0,00 MW	0,00 Mvar	0,00 MVA		
External Infeed	=	11,53 MW	5,74 Mvar	12,88 MVA		
Inter Grid Flow	=	0,00 MW	0,00 Mvar			
Load P(U)	=	11,21 MW	5,43 Mvar	12,46 MVA		
Load P(Un)	=	11,21 MW	5,43 Mvar	12,46 MVA		
Load P(Un-U)	=	-0,00 MW	-0,00 Mvar			
Motor Load	=	0,00 MW	0,00 Mvar	0,00 MVA		
Grid Losses	=	0,32 MW	0,31 Mvar			
Line Charging	=		0,00 Mvar			
Compensation ind.	=		0,00 Mvar			
Compensation cap.	=		0,00 Mvar			
Installed Capacity	=	0,00 MW				
Spinning Reserve	=	0,00 MW				
Total Power Factor:						
Generation	=	0,00 [-]				
Load/Motor	=	0,90 / 0,00 [-]				

# Case 1 – External Grid keeps active power balance


Grid: LV-Grid	System Stage: LV-Grid				Study Case: Study Case				Annex:	/ 3
	rtd.V [kV]	Bus - voltage [p.u.]	[kV]	[deg]	-10	-5	Voltage - Deviation [%]			
							0	+5	+10	
IA1	11,00	0,979	10,77	-0,97						
IA2	11,00	0,969	10,65	-0,67						
IA3	11,00	0,956	10,52	-0,33						
IA4	11,00	0,952	10,47	-0,21						
IA5	11,00	0,950	10,45	-0,15						
IB1	11,00	0,986	10,85	-1,16						
IB2	11,00	0,982	10,80	-1,04						
IB3	11,00	0,976	10,74	-0,89						
IB4	11,00	0,974	10,72	-0,82						
Bus HV	33,00	1,000	33,00	0,00						
Bus LSPl	11,00	0,989	10,88	-1,25						
IC1	11,00	0,983	10,81	-1,06						
IC2	11,00	0,975	10,72	-0,85						
IC3	11,00	0,972	10,70	-0,77						
IC4	11,00	0,968	10,65	-0,66						
IC5	11,00	0,967	10,64	-0,63						
Grid: LV-Grid	System Stage: LV-Grid				Study Case: Study Case				Annex:	/ 4
	rtd.V [kV]	Bus - voltage [p.u.]	[kV]	[deg]	-10	-5	Voltage - Deviation [%]			
							0	+5	+10	
IC6	11,00	0,964	10,61	-0,55						
							DigSILENT	Project:		
							PowerFactory			
							2019 SP4	Date: 2020-02-25		

# Different share of SSEG connected to the grid

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- X% SSEG connected
- This case represents the “worst” operating case when SSEG is connected. Sunny day with low load in the grid → maximum feed in to the power grid.
- All SSEG sources are contributing to the production of reactive power (inductive,  $\text{pf}=0.9$ )

## Case 2 – 10% of the hh install SSEG

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 10% SSEG connected



# Case 2 – 10% of the hh install SSEG

Grid: LV-Grid	System Stage: LV-Grid				Study Case: Study Case			Annex:	/ 3
	rtd.V [kV]	Bus - voltage [p.u.]	[kV]	[deg]	-10	-5	Voltage - Deviation [%]		
							0	+5	+10
A1	11,00	1,004	11,04	0,20					
A2	11,00	1,005	11,06	0,16					
A3	11,00	1,007	11,08	0,11					
A4	11,00	1,008	11,08	0,09					
A5	11,00	1,008	11,09	0,08					
B1	11,00	1,003	11,03	0,22					
B2	11,00	1,004	11,04	0,19					
B3	11,00	1,005	11,06	0,15					
B4	11,00	1,006	11,06	0,14					
Bus HV	33,00	1,000	33,00	0,00					
Bus LSP1	11,00	1,002	11,02	0,24					
C1	11,00	1,004	11,04	0,19					
C2	11,00	1,006	11,06	0,14					
C3	11,00	1,006	11,07	0,12					
C4	11,00	1,007	11,08	0,09					
C5	11,00	1,008	11,08	0,09					
Grid: LV-Grid	System Stage: LV-Grid				Study Case: Study Case			Annex:	/ 4
	rtd.V [kV]	Bus - voltage [p.u.]	[kV]	[deg]	-10	-5	Voltage - Deviation [%]		
							0	+5	+10
C6	11,00	1,008	11,09	0,07					
					DigSILENT		Project:		
					PowerFactory		Date: 2020-02-25		
					2019 SP4				

## Case 2 – 10% of the hh install SSEG

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 10% SSEG connected

- Grid losses: 0.01MW
- Voltages slightly increasing due to production and consumption locally, less power distributed throughout the grid
- Changed power flow – bottom up




# Case 2 – 10% of the hh install SSEG

				DigSILENT	Project:
				PowerFactory	
				2019 SP4	Date: 2020-02-25
-----					
Load Flow Calculation				Grid Summary	
AC Load Flow, balanced, positive sequence				Automatic Model Adaptation for Convergence	
Automatic tap adjustment of transformers				No	No
Consider reactive power limits				No	1,00 kVA
				Model Equations	0,10 %
-----					
Grid: LV-Grid		System Stage: LV-Grid		Study Case: Study Case	
				Annex: / 1	
Grid: LV-Grid		Summary			
-----					
No. of Substations	0	No. of Busbars	17	No. of Terminals	0
No. of 2-w Trfs.	1	No. of 3-w Trfs.	0	No. of syn. Machines	0
No. of Loads	15	No. of Shunts/Filters	0	No. of SVS	0
-----					
Generation	=	4,51 MW	2,19 Mvar	5,02 MVA	
External Infeed	=	-2,26 MW	-1,09 Mvar	2,51 MVA	
Inter Grid Flow	=	0,00 MW	0,00 Mvar		
Load P(U)	=	2,24 MW	1,09 Mvar	2,49 MVA	
Load P(Un)	=	2,24 MW	1,09 Mvar	2,49 MVA	
Load P(Un-U)	=	-0,00 MW	-0,00 Mvar		
Motor Load	=	0,00 MW	0,00 Mvar	0,00 MVA	
Grid Losses	=	0,01 MW	0,01 Mvar		
Line Charging	=		0,00 Mvar		
Compensation ind.	=		0,00 Mvar		
Compensation cap.	=		0,00 Mvar		
-----					
Installed Capacity	=	675,00 MW			
Spinning Reserve	=	0,00 MW			
-----					
Total Power Factor:					
Generation	=	0,90 [-]			
Load/Motor	=	0,90 / 0,00 [-]			



## Case 3 – 50% of the hh install SSEG

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 50% SSEG connected



# Case 3 – 50% of the hh install SSEG

	rtd.V [kV]	Bus - voltage [p.u.]	[kV]	[deg]	Voltage - Deviation [%]				
					-10	-5	0	+5	+10
A1	11,00	1,032	11,35	1,65					
A2	11,00	1,047	11,52	1,24					
A3	11,00	1,064	11,70	0,79					
A4	11,00	1,070	11,77	0,63					
A5	11,00	1,073	11,80	0,56					
B1	11,00	1,024	11,26	1,89					
B2	11,00	1,032	11,35	1,66					
B3	11,00	1,043	11,47	1,37					
B4	11,00	1,047	11,52	1,26					
Bus HV	33,00	1,000	33,00	0,00					
Bus LSP1	11,00	1,018	11,19	2,06					
C1	11,00	1,031	11,34	1,69					
C2	11,00	1,045	11,50	1,29					
C3	11,00	1,051	11,56	1,15					
C4	11,00	1,058	11,64	0,95					
C5	11,00	1,061	11,67	0,88					
D-									
Grid: LV-Grid      System Stage: LV-Grid        Study Case: Study Case        Annex:      / 4									
	rtd.V [kV]	Bus - voltage [p.u.]	[kV]	[deg]	-10	-5	0	+5	+10
C6	11,00	1,066	11,72	0,75					
D-									
							DigSILENT	Project:	
							PowerFactory		
							2019 SP4	Date: 2020-02-25	


## Case 3 – 50% of the hh install SSEG

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 50% SSEG connected

- Grid losses: 0.82MW
- Voltages increasing and in some cases exceeding the limits of +5% due to production exceeding consumption
- Changed power flow – bottom up

## Case 4 – 100% of the hh install SSEG

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 100% SSEG connected
- This case **is** the worst operating case when all hh has SSEG and is at low load
- 50% share of SSEG showed that the voltages increased above limits and de losses increased as well, what will happened now?





# Case 4 – 100% of the hh install SSEG

Grid: LV-Grid	System Stage: LV-Grid				Study Case: Study Case	Annex:	/ 3
	rtd.V [kV]	Bus - voltage [p.u.]	[kV]	[deg]	Voltage - Deviation [%]		
					-10	-5	0 +5 +10
IA1	11,00	1,064	11,71	3,29			
IA2	11,00	1,094	12,03	2,47			
IA3	11,00	1,128	12,40	1,61			
IA4	11,00	1,140	12,54	1,31			
IA5	11,00	1,145	12,59	1,18			
IB1	11,00	1,047	11,52	3,77			
IB2	11,00	1,064	11,71	3,32			
IB3	11,00	1,086	11,94	2,75			
IB4	11,00	1,094	12,04	2,53			
Bus HV	33,00	1,000	33,00	0,00			
Bus LSP1	11,00	1,035	11,39	4,12			
IC1	11,00	1,061	11,67	3,37			
IC2	11,00	1,090	11,99	2,59			
IC3	11,00	1,101	12,11	2,33			
IC4	11,00	1,116	12,27	1,95			
IC5	11,00	1,121	12,33	1,82			
/ 4							
Grid: LV-Grid	System Stage: LV-Grid				Study Case: Study Case	Annex:	/ 4
	rtd.V [kV]	Bus - voltage [p.u.]	[kV]	[deg]	Voltage - Deviation [%]		
					-10	-5	0 +5 +10
IC6	11,00	1,131	12,44	1,57			
Project: 2019 SP4 Date: 2020-02-25							

## Case 4 – 100% of the hh install SSEG

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 100% SSEG connected

No. of Loads	15	No. of :
Generation	=	45,14 MW
External Infeed	=	-39,62 MW
Inter Grid Flow	=	0,00 MW
Load P(U)	=	2,24 MW
Load P(Un)	=	2,24 MW
Load P(Un-U)	=	-0,00 MW
Motor Load	=	0,00 MW
Grid Losses	=	3,28 MW
Line Charging	=	
Compensation ind.	=	

- Grid losses: 3.28MW
- Voltages increasing and at all busses exceeding the limits of +5% due to production exceeding consumption
- Changed power flow – bottom up




# Break even

- How do we find the tipping point?
- 10% SSEG was ok, 50 % SSEG lead to exceeding the voltage increase limits and higher grid losses.



## Case 5 – 25% of the hh install SSEG

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 25% SSEG connected



# Case 5 – 25% of the hh install SSEG

	rtd.V [kV]	Bus - voltage [p.u.]	Bus - voltage [kV]	[deg]	Voltage - Deviation [%]				
					-10	-5	0	+5	+10
IA1	11,00	1,015	11,16	0,76					
IA2	11,00	1,021	11,23	0,57					
IA3	11,00	1,029	11,32	0,37					
IA4	11,00	1,032	11,35	0,29					
IA5	11,00	1,033	11,36	0,26					
IB1	11,00	1,011	11,12	0,87					
IB2	11,00	1,015	11,16	0,76					
IB3	11,00	1,020	11,22	0,63					
IB4	11,00	1,022	11,24	0,57					
Bus HV	33,00	1,000	33,00	0,00					
Bus LSP1	11,00	1,008	11,09	0,95					
IC1	11,00	1,014	11,16	0,77					
IC2	11,00	1,021	11,23	0,58					
IC3	11,00	1,023	11,26	0,52					
IC4	11,00	1,027	11,30	0,42					
IC5	11,00	1,028	11,31	0,39					
-----									
Grid: LV-Grid      System Stage: LV-Grid      Study Case: Study Case      Annex:									
	rtd.V [kV]	Bus - voltage [p.u.]	Bus - voltage [kV]	[deg]	-10	-5	0	+5	+10
IC6	11,00	1,031	11,34	0,32					

## Case 5 – 25% of the hh install SSEG

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 25% SSEG connected

Generation	=	11,29	MW
External Infeed	=	-8,87	MW
Inter Grid Flow	=	0,00	MW
Load P(U)	=	2,24	MW
Load P(Un)	=	2,24	MW
Load P(Un-U)	=	-0,00	MW
Motor Load	=	0,00	MW
Grid Losses	=	0,17	MW
Line Charging	=		
Compensation ind.	=		

- Grid losses: 0.17MW
- Voltages increasing at all busses but within limits
- Changed power flow – bottom up

# Break even

- Can we go even further?



## Case 6 – 35% of the hh install SSEG

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 35% SSEG connected







## Case 6 – 35% of the hh install SSEG

Grid: LV-Grid		System Stage: LV-Grid			Study Case: Study Case		Annex: / 3		
	rtd.V	Bus - voltage			Voltage - Deviation [%]				
	[kV]	[p.u.]	[kV]	[deg]	-10	-5	0	+5	+10
IA1	11,00	1,022	11,24	1,12					
IA2	11,00	1,032	11,35	0,85					
IA3	11,00	1,043	11,48	0,54					
IA4	11,00	1,047	11,52	0,43					
IA5	11,00	1,049	11,54	0,38					
IB1	11,00	1,016	11,18	1,28					
IB2	11,00	1,022	11,24	1,13					
IB3	11,00	1,029	11,32	0,93					
IB4	11,00	1,032	11,35	0,85					
Bus HV	33,00	1,000	33,00	0,00					
Bus LSP1	11,00	1,012	11,13	1,40					
IC1	11,00	1,021	11,23	1,15					
IC2	11,00	1,031	11,34	0,87					
IC3	11,00	1,034	11,38	0,78					
IC4	11,00	1,040	11,44	0,64					
IC5	11,00	1,041	11,46	0,59					

Grid: LV-Grid		System Stage: LV-Grid			Study Case: Study Case		Annex: / 4		
	rtd.V	Bus - voltage			Voltage - Deviation [%]				
	[kV]	[p.u.]	[kV]	[deg]	-10	-5	0	+5	+10
IC6	11,00	1,045	11,49	0,49					

		DigSILENT		Project:	
		PowerFactory		-----	
		2019 SP4		Date: 2020-02-25	



## Case 6 – 35% of the hh install SSEG

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 35% SSEG connected

Generation	=	15,80	MW
External Infeed	=	-13,18	MW
Inter Grid Flow	=	0,00	MW
Load P(U)	=	2,24	MW
Load P(Un)	=	2,24	MW
Load P(Un-U)	=	-0,00	MW
Motor Load	=	0,00	MW
Grid Losses	=	0,38	MW
Line Charging	=		
Compensation ind.	=		

- Grid losses: 0.38MW
- Voltages increasing at all busses but within limits
- Changed power flow – bottom up

# Conclusion




	Grid losses [MW]	Exceeding voltage limits?
Case 1 - 0 % SSEG	0.32	no
Case 2 - 10 % SSEG	0.01	no
Case 3 - 50 % SSEG	0.82	some busses
Case 4 - 100 % SSEG	3.28	all busses
Case 5 - 25 % SSEG	0.17	no
Case 6 - 35 % SSEG	0.38	no

# More SSEG?


- What can be done to accommodate 35 % SSEG?
- How will different solutions affect the grid losses?

## Case 7 – 35% of the hh install SSEG, reactors

- The power grid company installs Shunt reactors at the end of Feeder A, B and C
- The reactors should reduce the voltage at the end busses in Feeder A, B and C
- Can these reactors push the tipping point for allowed share of SSEG in this grid to extend to 35%?
- What will happen to the grid losses?



Before adding reactors





# Case 7 – 35% of the hh install SSEG, reactors

Grid: LV-Grid		System Stage: LV-Grid			Study Case: Study Case		Annex:		/ 3	
	rtd.V	Bus - voltage			Voltage - Deviation [%]					
	[kV]	[p.u.]	[kV]	[deg]	-10	-5	0	+5	+10	
A1	11,00	1,012	11,13	1,43						
A2	11,00	1,022	11,24	1,50						
A3	11,00	1,034	11,37	1,73						
A4	11,00	1,038	11,41	1,89						
A5	11,00	1,040	11,43	2,07						
B1	11,00	1,006	11,07	1,39						
B2	11,00	1,012	11,13	1,41						
B3	11,00	1,019	11,21	1,56						
B4	11,00	1,022	11,24	1,75						
Bus HV	33,00	1,000	33,00	0,00						
Bus LSP1	11,00	1,002	11,02	1,42						
C1	11,00	1,011	11,12	1,29						
C2	11,00	1,021	11,23	1,17						
C3	11,00	1,025	11,27	1,15						
C4	11,00	1,030	11,33	1,13						
C5	11,00	1,032	11,35	1,15						
Grid: LV-Grid		System Stage: LV-Grid			Study Case: Study Case		Annex:		/ 4	
	rtd.V	Bus - voltage			Voltage - Deviation [%]					
	[kV]	[p.u.]	[kV]	[deg]	-10	-5	0	+5	+10	
C6	11,00	1,035	11,39	1,31						
							DiGSILENT	Project:		
							PowerFactory			
							2019 SP4	Date:	2020-04-03	



## Case 7 – 35% of the hh install SSEG, reactors


- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 35% SSEG connected
- Reactors are added at the end of Feeder A, B and C

NO. OF LOADS	IS	NO. OF LOADS
Generation	=	15,80 MW
External Infeed	=	-13,22 MW
Inter Grid Flow	=	0,00 MW
Load P(U)	=	2,24 MW
Load P(Un)	=	2,24 MW
Load P(Un-U)	=	0,00 MW
Motor Load	=	0,00 MW
Grid Losses	=	0,34 MW
Line Charging	=	
Compensation ind.	=	

- Grid losses: 0.34MW
- Voltages decreasing thanks to reactors
- Changed power flow – bottom up

## Case 8 – 35% of the hh install SSEG, cap. SSEG

- The Shunt reactors are set out of service for all the feeders
- Instead the power factor of the PV inverters are changed to **0.9 capacitive**
- This gives that the PV-sources now are consuming reactive power
- What will happen to the grid losses?



# Case 8 – 35% of the hh install SSEG, cap. SSEG

Grid: LV-Grid		System Stage: LV-Grid		Study Case: Study Case		Annex:		/ 3	
	rtd.V	Bus - voltage		Voltage - Deviation [%]					
	[kV]	[p.u.]	[kV]	[deg]	-10	-5	0	+5	+10
IA1	11,00	0,993	10,92	1,84					
IA2	11,00	1,003	11,04	2,24					
IA3	11,00	1,015	11,17	2,69					
IA4	11,00	1,019	11,21	2,85					
IA5	11,00	1,021	11,23	2,92					
IB1	11,00	0,987	10,86	1,59					
IB2	11,00	0,993	10,92	1,80					
IB3	11,00	1,001	11,01	2,07					
IB4	11,00	1,004	11,04	2,18					
Bus HV	33,00	1,000	33,00	0,00					
Bus LSP1	11,00	0,983	10,81	1,43					
IC1	11,00	0,992	10,92	1,78					
IC2	11,00	1,003	11,03	2,15					
IC3	11,00	1,006	11,07	2,28					
IC4	11,00	1,012	11,13	2,47					
IC5	11,00	1,013	11,15	2,53					
Grid: LV-Grid		System Stage: LV-Grid		Study Case: Study Case		Annex:		/ 4	
	rtd.V	Bus - voltage		Voltage - Deviation [%]					
	[kV]	[p.u.]	[kV]	[deg]	-10	-5	0	+5	+10
IC6	11,00	1,017	11,19	2,66					
					DigSILENT		Project:		
					PowerFactory		Date: 2020-04-03		
					2019 SP4				

## Case 8 – 35% of the hh install SSEG, cap. SSEG


- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 35% SSEG connected
- PV-sources 0.9 capacitive

NO. OF LOADS		AS	NO. OF SIMUL
Generation	=	15,80 MW	
External Infeed	=	-13,10 MW	
Inter Grid Flow	=	0,00 MW	
Load P(U)	=	2,24 MW	
Load P(Un)	=	2,24 MW	
Load P(Un-U)	=	0,00 MW	
Motor Load	=	0,00 MW	
Grid Losses	=	0,46 MW	
Line Charging	=		
Compensation ind.	=		

- Grid losses: 0.46MW
- Voltages increasing at all busses but within limits
- Changed power flow – bottom up

## Case 9 – 35% of the hh install SSEG, cap. SSEG and reactor at MV bus

- The SSEG systems are still capacitive
- A shunt reactor at the MV bus is added





# Case 9 – 35% of the hh install SSEG, cap. SSEG and reactor at MV bus

Factor at MV bus

Grid: LV-Grid		System Stage: LV-Grid		Study Case: Study Case		Annex:		/ 3	
	rtd.V [kV]	Bus - voltage [p.u.]	Bus - voltage [kV]	deg	Voltage - Deviation [%]				
					-10	-5	0	+5	+10
IA1	11,00	0,982	10,80	1,86					
IA2	11,00	0,993	10,92	2,28					
IA3	11,00	1,004	11,05	2,74					
IA4	11,00	1,009	11,09	2,90					
IA5	11,00	1,010	11,11	2,97					
IB1	11,00	0,976	10,74	1,61					
IB2	11,00	0,982	10,80	1,83					
IB3	11,00	0,990	10,89	2,10					
IB4	11,00	0,993	10,92	2,22					
Bus HV	33,00	1,000	33,00	0,00					
Bus LSP1	11,00	0,972	10,69	1,45					
IC1	11,00	0,981	10,79	1,80					
IC2	11,00	0,992	10,91	2,18					
IC3	11,00	0,995	10,95	2,31					
IC4	11,00	1,001	11,01	2,51					
IC5	11,00	1,003	11,03	2,57					
Grid: LV-Grid		System Stage: LV-Grid		Study Case: Study Case		Annex:		/ 4	
	rtd.V [kV]	Bus - voltage [p.u.]	Bus - voltage [kV]	deg	Voltage - Deviation [%]				
					-10	-5	0	+5	+10
IC6	11,00	1,006	11,07	2,70					
				DigSILENT		Project:			
				PowerFactory		Date:		2020-04-20	
				2019 SP4					

## Case 9 – 35% of the hh install SSEG, cap. SSEG and reactor at MV bus


- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 35% SSEG connected

NO. OF LOADS	13	NO. OF GEN
Generation	=	15,80 MW
External Infeed	=	-13,09 MW
Inter Grid Flow	=	0,00 MW
Load P(U)	=	2,24 MW
Load P(Un)	=	2,24 MW
Load P(Un-U)	=	-0,00 MW
Motor Load	=	0,00 MW
Grid Losses	=	0,47 MW
Line Charging	=	
Compensation ind.	=	

- Grid losses: 0.47MW
- Voltages decreasing, within limits
- Changed power flow – bottom up

## Case 10 – 35% of the hh install SSEG, ind. SSEG and reactor at MV bus

- The SSEG systems are inductive (default)
- A shunt reactor at the MV bus is added





## Case 10 – 35% of the hh install SSEG, ind. SSEG and reactor at MV bus

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 35% SSEG connected


	No. of Loads	15	No. of Shunts
Generation	=	15,80 MW	
External Infeed	=	-13,18 MW	
Inter Grid Flow	=	0,00 MW	
Load P(U)	=	2,24 MW	
Load P(Un)	=	2,24 MW	
Load P(Un-U)	=	0,00 MW	
Motor Load	=	0,00 MW	
Grid Losses	=	0,38 MW	
Line Charging	=		
Compensation Ind	=		

- Grid losses: 0.38MW
- Reduced voltage at some busses

## Case 11 – 35% of the hh install SSEG, cap. and ind. SSEG

- Every second SSEG systems is capacitive





# Case 11 – 35% of the hh install SSEG, cap. and ind. SSEG

Grid: LV-Grid	System Stage: LV-Grid				Study Case: Study Case	Annex:	/ 3
	rtd.V [kV]	Bus - voltage [p.u.]	[kV]	[deg]	Voltage - Deviation [%]		
					-10	-5	0 +5 +10
A1	11,00	1,009	11,10	1,42			
A2	11,00	1,019	11,21	1,48			
A3	11,00	1,031	11,34	1,41			
A4	11,00	1,035	11,38	1,42			
A5	11,00	1,037	11,41	1,37			
B1	11,00	1,003	11,04	1,44			
B2	11,00	1,009	11,10	1,39			
B3	11,00	1,016	11,18	1,41			
B4	11,00	1,019	11,21	1,33			
Bus HV	33,00	1,000	33,00	0,00			
Bus LSP1	11,00	0,999	10,99	1,42			
C1	11,00	1,008	11,09	1,45			
C2	11,00	1,018	11,20	1,42			
C3	11,00	1,022	11,24	1,42			
C4	11,00	1,027	11,30	1,38			
C5	11,00	1,029	11,32	1,38			
Grid: LV-Grid	System Stage: LV-Grid				Study Case: Study Case	Annex:	/ 4
	rtd.V [kV]	Bus - voltage [p.u.]	[kV]	[deg]	Voltage - Deviation [%]		
					-10	-5	0 +5 +10
C6	11,00	1,033	11,36	1,28			
					DiGSILENT	Project:	
					PowerFactory		
					2019 SP4	Date: 2020-04-20	

# Case 11 – 35% of the hh install SSEG, cap. and ind. SSEG


- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 35% SSEG connected

Generation	=	15,80	MW
External Infeed	=	-13,25	MW
Inter Grid Flow	=	0,00	MW
Load P(U)	=	2,24	MW
Load P(Un)	=	2,24	MW
Load P(Un-U)	=	-0,00	MW
Motor Load	=	0,00	MW
Grid Losses	=	0,32	MW
Line Charging	=		

- Grid losses: 0.32MW
- Voltages within limits
- Changed power flow – bottom up

## Case 12 – 35% of the hh install SSEG, cap. and ind. SSEG and reactor at MV bus

- Every second SSEG systems is capacitive
- A shunt reactor at the MV bus is added



# G and reactor at MV bus

	rtd.V [kV]	Bus - voltage [p.u.]	voltage [kV]	angle [deg]	Voltage - Deviation [%]
A1	11,00	0,998	10,98	1,44	-0,2%
A2	11,00	1,008	11,09	1,50	+0,9%
A3	11,00	1,020	11,22	1,42	+1,8%
A4	11,00	1,024	11,27	1,44	+2,2%
A5	11,00	1,026	11,29	1,39	+2,4%
B1	11,00	0,992	10,91	1,45	-0,4%
B2	11,00	0,998	10,98	1,40	-0,2%
B3	11,00	1,005	11,06	1,42	+0,5%
B4	11,00	1,009	11,09	1,34	+0,8%
Bus HV	33,00	1,000	33,00	0,00	0,0%
LSP1	11,00	0,988	10,87	1,44	-0,6%
C1	11,00	0,997	10,97	1,47	-0,3%
C2	11,00	1,008	11,08	1,43	+0,9%
C3	11,00	1,011	11,12	1,44	+1,1%
C4	11,00	1,016	11,18	1,39	+1,5%
C5	11,00	1,018	11,20	1,39	+1,7%

	rtd.V [kV]	Bus - voltage [p.u.]	voltage [kV]	angle [deg]	Voltage - Deviation [%]
C6	11,00	1,022	11,24	1,29	+2,0%

DigSILENT Project:  
PowerFactory  
2019 SP4 Date: 2020-04-20

## Case 12 – 35% of the hh install SSEG, cap. and ind. SSEG and reactor at MV bus

- External Grid keeps active power balance (slack)
- The house hold loads are at their lowest
- 35% SSEG connected

No. of Loads	15	No. of Shunts/F
Generation	=	15,80 MW
External Infeed	=	-13,24 MW
Inter Grid Flow	=	0,00 MW
Load P(U)	=	2,24 MW
Load P(Un)	=	2,24 MW
Load P(Un-U)	=	-0,00 MW
Motor Load	=	0,00 MW
Grid Losses	=	0,32 MW
Line Charging	=	

- Grid losses: 0.32MW
- Voltages are decreased – more slack
- Changed power flow – bottom up



# Conclusion

		Grid losses [MW]	Exceeding voltage limits?
	Case 1 - 0 % SSEG	0.32	no
→	Case 7 - 35 % SSEG, reactors at end of feeders	0.34	no
	Case 8 - 35 % SSEG, cap. SSEG	0.46	no
	Case 9 - 35 % SSEG, cap SSEG & Reactor at main bus	0.47	no
→	Case 10 - 35 % SSEG, reactor at main bus	0.38	no
→	Case 11 - 35 % SSEG, cap. and ind. SSEG	0.32	no
	Case 12 - 35 % SSEG, cap. and ind. SSEG & Reactor at main bus	0.32	no

# Homework

